



# Clean Water Act §316(b) Compliance— Cooling Water Intake Structure Case Studies: Part II

Presented by:

Julia Wozniak, EA Engineering, Science, and Technology, Inc., PBC


# Outline of Topics to be Covered

- Overview of the Final Phase II §316(b) Rule
- Applicability and Requirements
- Definitions (*and things lacking definition*)
  
- CASE STUDY REVISITED: **Citizens Energy Perry K Steam Plant**
- Chronology of Agency Interaction
- Results of Required Studies Performed in 2023
- Next Steps (i.e. “*Are we done yet?*”)
  
- Other Case Studies
  
- Wrap-Up: Lessons Learned, Expectations for Current and Potential Future Cooling Water Users

# Basis of Clean Water Act §316(b) Rule

**According to USEPA, withdrawal of cooling water from Waters of the United States (WOTUS) for power production and other industrial purposes:**

- **Accounts for over half of all water withdrawn in the U.S. each year**
- **Removes and kills billions of aquatic organisms each year**
- **Impacts primarily early life stages of fish and shellfish**



# The §316(b) Rule is Unique

- The only USEPA rule that applies to facility water INTAKES
- Applies to COOLING WATER withdrawn from a Water of the U.S. (WOTUS)
- Designed to provide protections for Fish and Shellfish
- Federal Rule with wide applicability, implemented by State Permitting Authority; States may be more stringent


# Rule Applicability Criteria:

1. Facility is regulated through an individual NPDES permit;
2. Has a cumulative design intake flow (DIF) of greater than **Two million gallons per day (MGD)** withdrawn from a WOTUS; and,
3. **25% or more of the water withdrawn** is used exclusively for cooling water purposes
  - *Facilities using cooling water sourced from a WOTUS that do not meet all of these conditions may still be subject to **Best Professional Judgement (BPJ)** requirements established by their permitting authority*

# EPA's Definition of Cooling Water:

- **COOLING WATER** means water used for contact or non-contact cooling, including water used for **equipment cooling, evaporative cooling tower makeup, and/or dilution of effluent heat content**
- Does NOT include:
  - Public utility-supplied or reclaimed water, treated effluent, or water recycled for cooling use from other on-site processes
  - *Usually* does not include cooling water withdrawn from a man-made reservoir or perched cooling pond—BUT supporting information must be submitted to the state regulator for concurrence

# Regulatory Timeline: 42 Years!



*Now, almost TEN years later, states and facilities are still working on implementation of the Rule...*

# Purpose of the §316(b) Rule:

- Minimize **Adverse Environmental Impacts** (AEI) from Impingement and Entrainment of aquatic organisms resulting from use of Cooling Water Intake Structures (CWIS)
- Includes both fish and shellfish





# Types of Facilities Subject to §316(b):

- **Steam Electric Power Plants**
- **Paper Mills**
- **Chemical Companies**
- **Steel /Aluminum Mills /Foundries**
- **Oil Refineries**
- **Packaging /Container Manufacturers**
- **Recycling/Resource Recovery**
- **Grain Processing/Milling**
- **Sugar Refining**
- **Lumber Mills**
  
- **In addition, any large building that uses surface water for HVAC cooling purposes and meets the other three criteria is subject to the §316(b) Rule (e.g. **Data Centers, High Rise Office Buildings**)**



# What is Adverse Environmental Impact?

- **No definition is provided by USEPA**

Prior to the issuance of the 2014 Final Rule, AEI was determined by state regulatory agencies based on Species-Specific, Population-Level Impacts; controls were required when determined to be necessary, based on documented effects


- **2014 Final Rule:**

- ◆ **One fish impinged or entrained = AEI?**
- ◆ **Left up to the states, with little guidance**



# Types of Impact:

- ✓ **IMPINGEMENT:** entrapment of any life stages of fish / shellfish on the outer part of an intake structure or against a screening device during periods of intake water withdrawal
- ✓ **ENTRAINMENT:** any life stages of fish / shellfish in the intake water flow entering and passing through a cooling water intake structure and into a cooling water system, including the condenser or heat exchanger



# Impingement:



Source: Delaware.sierraclub.org



Source: EA



Source: EA



Source: Riverkeeper.org

Size Range: > 3/8 inch (9.5 mm)



# Entrainment:



Source:  
News.nationalgeographic.com



Source: irrec.ifas.ufl.edu



Source: EA



Source: EA

Typical Size Range: 0.5mm and up.  
Fine mesh screen controls sized to match head or egg  
dimensions

# “(r)” requirements – 40 CFR §122.21(r):

Information required with each NPDES permit renewal application for Existing Facilities Subject to §316(b)

- ◆ **Actual intake flow >2 MGD: (r)(2) through (r)(8)**
- ◆ **Actual intake flow >125 MGD must also submit (r)(9) through (r)(13)**—APPLIES MOSTLY TO LARGE POWER GENERATORS
- **Waivers of “r” requirements for man-made lakes/reservoirs stocked and managed by resource agencies may be granted, as long as no threatened or endangered species or critical habitats are present**
- **After first round of §316(b) in NPDES permits, permittees can request reduced (r) report submittal requirements 2.5 years before permit expiration---no guarantee that state will grant such requests**

# §122.21(r) Reports: Required for All §316(b) Facilities

- (r)(2): Source Water Physical Data
- (r)(3): Cooling Water Intake Structure Data
- (r)(4): Source Water Baseline Biological Characterization Data
- (r)(5): Cooling Water System Data
- (r)(6): Intended Method of Compliance with Impingement Mortality Standard
- (r)(7): Existing Entrainment Performance Studies
- (r)(8): Operational Status

## Additional §122.21(r) Reports Required for >125 MGD Intake Flow

- (r)(9): Entrainment Characterization Study (2 years of data)
  - (r)(10): Comprehensive Technical Feasibility and Cost Evaluation Study
  - (r)(11): Benefits Evaluation Study
  - (r)(12): Non-Water Quality and Other Environmental Impacts Study
  - (r)(13): Peer Review of (r)(10-12) Reports
- State must make determination on facility entrainment compliance status before imposing impingement controls



# Entrainment Control

**GOAL: Reduce overall cooling water volume withdrawn**

**TWO PRIMARY OPTIONS: (Both Very Expensive)**

- Install specialized **Fine-Mesh Intake Screens** (as small as 0.5 mm)
- Retrofit to a **Closed Cycle Recirculating System (CCRS)**



- **Site-specific BTA** determined by regulator based on review of information in “r” reports; BPJ for facilities <125 MGD

# Seven Impingement Control Options §125.94(b):

## ■ Pre-Approved Technologies:

(no on-going biological compliance monitoring required)

- Closed Cycle Recirculating System (CCRS)
- Design Intake Velocity <0.5 fps
- Existing Off-Shore Velocity Cap

## ■ Streamlined Compliance Alternatives:

(require a 2-year optimization study)

- Actual Intake Velocity <0.5 fps
- **Modified Traveling Screens with Fish Return System**
- **System of Technologies Approach**

## ■ 12-Month Performance Standard of No More Than 24% Mortality


- As demonstrated through ON-GOING biological monitoring (i.e., for life of plant...)

# Impingement Control

- Fine Mesh Screen/Off-Shore Intake



- Modified Traveling Screen System



- Fish Return System



- Optimization Studies




# A Few “Off-Ramps” Are Also Provided by the Rule for Impingement (§125.94(c)(10)(11)(12):

- **Reuse of other water for cooling purposes**
  
- ***De minimis* rate of impingement**
  - ◆ *“In limited circumstances, rates of impingement may be so low at a facility that additional impingement controls may not be justified.”*
  - ◆ No definition or other guidance on what constitutes “*de minimis*” is provided in the Rule
  - ◆ This determination is to be made by the state regulator
  
- **Low-capacity utilization power generating units**



# CASE STUDY: Citizens Energy Perry K Steam Plant—Indianapolis, Indiana


- ✓ Original plant and boilers (long since removed) constructed in 1893 to provide electricity to the Edison electric light circuit to Union Station
- ✓ Primary output shifted to steam at the turn of the 20th century to meet the demands of the growing industrial users in SW downtown Indianapolis
- ✓ Today: Second largest district steam system in the United States
- ✓ Steam sold to chilled water business to drive chillers that provide district cooling



*Engines and generators in the original Kentucky Avenue plant, as pictured in 1897.*



# Location of Perry K CWIS on the White River



Buried concrete inlet canal that brings water from the Screen House to the softener at Perry K

Perry K Steam Plant (NW corner of South & West Streets)

# Perry K and the Clean Water Act



- **316(b):** No prior permit requirements, until Final Rule was issued
- **CWIS meets applicability criteria under existing facilities (Phase II) rule:**
  - **>2 MGD Cooling Water Flow**
  - **>25% of Intake Flow Used for Cooling**
  - **Operations Regulated by an NPDES Permit (IN0004677)**



# Cooling Water Use at Perry K

- **100% surface water used at the plant**
  - for once-through cooling water and boiler water
  - Connection to public water system for emergency use only
- **Boiler water treated through hot process water softener, anthracite filtration and zeolite polishing before entering the boilers**
- **Facility Specs:**
  - ◆ 7 boilers capable of producing approximately 1.9 million pounds per hour of steam
  - ◆ Natural gas is the primary fuel for all boilers; Boilers #17 and #18 have oil-firing capability for emergency



# §316(b) Facts for Perry K

- **Cooling Water Source: West Fork of White River**
  - ◆ A Water of the U.S. and also an Urbanized Stream
  - ◆ Long-Term (1931-2022) Annual Mean Flow of 1,603 cfs
  - ◆  $Q_{7,10}$ : 69 cfs
  
- **Design Intake Flow: 42.3 MGD (65.43 cfs)—*theoretical only*\***
  - ◆ Only 4.1% of annual mean flow of the source water
  
- **Actual Intake Flow: 16.7 MGD (25.83 cfs)**
  - ◆ Only 1.6% of annual mean flow of the source water
  
- (Final Rule states that no entrainment controls are necessary for those facilities that withdraw less than 5% of annual mean source water flow)
  
- **Intake Velocity: <0.5 fps at design flow**
  - (i.e. below USEPA criteria for impingement effects)

# Perry K NPDES §316(b) History

- Section 122.21(r)(2) through (r)(8) information, including the results of a year-long impingement study conducted in 2013-2014, was provided to the Indiana Department of Environmental Management (IDEM) by Citizens concurrent with the July 2016 Perry K Plant NPDES permit renewal application.
- Data showed that the existing facility CWIS configuration and operation met the criteria to be considered under **§125.94(c)(11)—*De minimis* rate of impingement**
- In IDEM's 2016 BPJ determination, they fundamentally agreed, based on the information provided at that time, that **the existing configuration and operation of the Perry K CWIS was compliant with the intent of the Final Rule, in that it represented a BPJ determination of BTA for the minimization of adverse environmental impacts**

# Perry K NPDES §316(b) History—(continued)

- HOWEVER, the official response from IDEM was that they were “...unable at this time to determine whether a ‘de minimis’ determination is appropriate”
- Additional information was submitted to IDEM to provide support for both a BTA Entrainment decision (June 2019), as well as further support for a *de minimis* determination
- Discussions were held with IDEM staff during the permit renewal process to try to limit 316(b) requirements based on submitted information--without much success
- **No technical explanation has ever been provided by IDEM as to why the *de minimis* exemption could not be granted for the Perry K Plant, other than the fact that they did not want to support it**

# 2013-2014 Impingement Study

- A total of **11 fish** with a **combined weight of 3.2 ounces** was collected over an entire year; six common species
  - Extrapolated values, based on AIF, were 109 fish, weighing a total of 3.38 pounds
  - No federal or state threatened or endangered species were found
  - Extrapolated Impingement numbers show collection dominated by Bluegill (35%) and by Gizzard Shad (25%), which is considered as an invasive species in the state of Indiana
- **But IDEM still doesn't consider this to be *de minimis*?**

# EA Retained to Assist Citizens in 2021

- EA was founded in 1973 to provide 316(a)/316(b) support to industry
- EA has performed 316(b)-related work in 14 different states, at over 180 different facilities on various source waters
- EA's expertise includes the design of site-specific study plans, execution of field work, lab identification and processing, report preparation, and continuing technical and regulatory negotiation support
- EA worked with Citizens to develop a proposed impingement "control" option that would satisfy IDEM



# Perry K NPDES Permit Requirements

- IDEM concurred with the selection of BTA impingement compliance alternative 40 CFR §125.94(c)(6): **System of Technologies Approach**
  - ◆ This option required **an additional year of impingement data**, even through the facility had already determined minimal impingement
  - ◆ A **site-specific entrainment study** was also required, even through the facility already met the low flow percentage test
  - ◆ These requirements were incorporated into the subsequent NPDES Permit— issued January 1, 2022
- Study Plans were required to be submitted and approved by IDEM prior to the initiation of work
  - ◆ Submitted for review: July 2023
  - ◆ “Tentative” approval: December 2023
  - ◆ Study Start date: January 2023 (IM)/April 2023 (ENT)
  - ◆ Final approval: May 2023 (AFTER studies began!)



# Field Work Site: Perry K CWIS





# Impingement Sampling Set-Up



- 36 individual 24-hour samples taken throughout the course of the year
- Photos of basket required by IDEM to be taken during each event prior to processing





# The Total 2023 Impingement “Catch”:

- After 36 individual 24-hour sampling events, under a variety of river, weather, and facility operating conditions, a grand total of **13 fish** were collected---along with an abundance of Chinese Mystery Snails and Rusty Crayfish (both invasive)




# 2013/2014 and 2023 Impingement Results

- 33 separate 24-hr sampling events over 12-month period
- 11 Individual Fish representing 6 common species:
  - ◆ Bluegill
  - ◆ Flathead Catfish
  - ◆ Largemouth Bass
  - ◆ Longear Sunfish
  - ◆ Orangespotted Sunfish
  - ◆ White Crappie
  - ◆ Gizzard Shad
- Total combined weight: 3.2 ounces

- 36 separate 24-hr sampling events over a calendar year
- 13 Individual Fish representing 4 common species:
  - ◆ Bluegill
  - ◆ Flathead Catfish
  - ◆ Largemouth Bass
  - ◆ Longear Sunfish
- Total combined weight: 4.4 ounces

# Comparison to Other Facilities on Similar Waterways



# Impingement Technology Optimization

- Report submitted to IDEM in March 2024
- Provided data and documentation to show that there were no correlations between facility operations, weather, river flow and impingement numbers
- Reiterated the same *de minimis* levels of impingement found in site-specific studies separated by approximately 10 years
- Therefore, concluded that there were no opportunities for further “optimization” of impingement numbers (i.e. facility is already BTA)
- **IDEM RESPONSE: None yet...**



# Entrainment Sampling Set-Up




Water was pumped from intake canal through 3/8" mesh strainer and put into 335 $\mu$ m net—fish eggs and larvae were retained, preserved, and identified in EA's laboratory

16 sample events with three depth-integrated diurnal samples per date from April through September 2023 for a total of 48 individual samples



# Final 2023 Entrainment Results:

- Very small number of fish eggs and larvae collected (N = 1588)
- Typical Distribution based on Spawning Time
- All Common Species/Taxa
- Over 25% composed of fragile / state invasive species
- No State or Federally Threatened or Endangered Species



# What's Next for Perry K Regarding §316(b)?

- Final Entrainment Report is due 36 months from the approval of the study plan (May 2026)
- Request for reduced §316(b) information for the next permit renewal needs to be submitted by June 2024—2.5 years before current NPDES Permit expires
- New permit must contain IDEM's final determination on Entrainment BTA, as well as an agency opinion regarding Perry K's impingement mortality optimization status
- **BEST CASE: Perry K's CWIS will be found to be BTA for both Impingement and Entrainment with no additional technologies or operational measures needed**

# Similar Case Studies: Midwest

- EA was responsible for all aspects of §316(b) submittal requirements for a large independent power producer with seven fossil-fueled facilities on five different waterways:

Lake Michigan (1)

South Branch of Chicago River (1)





Chicago Sanitary and Ship Canal (2)

Lower Des Plaines River (2)

Illinois River (1)



# 316(b) Compliance Outcomes



# Similar Case Studies--Midwest

- EA developed and executed a year-long impingement study for large corn-processing industry, along with required reports

## OUTCOME:

- *De minimis* determination for impingement (342 organisms), no T&E species
- BTA determination for entrainment, based on low flow in proportion to source water (<5%)





# Similar Case Study: East Coast

- EA was responsible for all aspects of §316(b) requirements for multi-unit power plant on the east coast, located in tidal waters:



# Similar Case Study: East Coast

- **Work included two years of entrainment sampling, as well as review of prior impingement study results (included commercially important Blue Crab)**
  - ◆ **122.21(r)(9-13) prepared by consultant team and submitted in January 2024**
  - ◆ **122.21(r)(2-8)—in progress**
- **Expected Result:**
  - ◆ **Low capacity utilization determination for impingement / entrainment BTA based on low flow volume (due to peaking operation)**
  - ◆ **Short remaining life of plant will also influence regulator's decision regarding need for any additional impingement / entrainment controls**

# §316(b) Lessons Learned


- Every state regulatory agency handles §316(b) differently, even though they are all bound by the same federal rule baseline requirements
- Even though the Rule allows for state flexibility and the power to make BPJ decisions, some state regulators are hesitant, even when provided with an abundance of supporting information
- Requiring additional studies to delay the decision-making process places an unwarranted financial burden on permittees to collect additional data that is not always necessary to make an informed decision
- There should be a strong technical and/or regulatory basis for requests for additional data collection



# Considering a New Facility That Uses Cooling Water?

- The Phase I §316(b) Rule requires that new facilities with WOTUS source water be designed at the outset to be fully compliant for impingement and entrainment control
  - ◆ Through-screen intake velocity of  $<0.5$  fps
  - ◆ Intake flow commensurate with closed cycle cooling
- **Even so, There are MANY additional on-going reporting requirements**
  - ◆ Impingement and Entrainment studies to demonstrate no impact
  - ◆ Velocity measurements to document  $<0.5$  fps


■ **NO FREE LUNCH!**



# #1 Advice: Know the Ins and Outs of the Rule

- Do your homework--Visit the USEPA website: <https://www.epa.gov/cooling-water-intakes>
- Be proactive in identifying facility characteristics and data that will help lead to a BTA determination (for either impingement and/or entrainment, as applicable)
- Work with your regulator as needed to help them better understand the Rule requirements, as well as their responsibility to make reasonable BTA decisions supported by defensible data
- Look for precedents in your own state, or others, that can help make your case
- Be prepared to collect additional data anyway (even if you don't think you need it)
- Get help from a knowledgeable, experienced consultant

# If your facility does not fall under the Rule:



# If you are unsure if your facility is or could be subject to §316(b) requirements:

- **Don't** interpret the Rule requirements in a vacuum
- **Do** ask an experienced consultant, or other knowledgeable source, for guidance and recommendations



# *Thank You!*

Julia Wozniak

[jwozniak@eaest.com](mailto:jwozniak@eaest.com)

EA Engineering, Science, and Technology, Inc., PBC



(P.S. We do more than just §316(b)/fisheries work: [eaest.com](http://eaest.com))